

QA Series



QA19



QA0817

Addressable Devices

Characteristics

QA19 Addressable Manual Call Point

- Signal will directly sent to panel.
- Address coding by Dip switch makes the job easier.
- Fire proof plastic.
- Indicator above fire alarm push burron is to confirm the alarm signal transfer.
- There are phone jack reset button behind the cover cap.

QA0817 Addressable Manual Call Point

- Signal will directly sent to panel.
- Address coding by Dip switch makes the job easier.
- Fire proof plastic.
- Clear protection cover is also available.

Specifications

Model	QA19	QA0817
Purpose	Signal will directly sent to panel	
System Connected	Control panel loop	
Input Source	Loop signal	
Output Contacts/Load	N/A	
Address Coding	Binary	
Operating Voltage	26 VDC	
Alarm Current	6mA	
Quiescent Current	850µA	
Ambient Temperature	0°C ~ +50°C	
Material	Fire-proof plastic	
Color	Red	
Dimensions(mm)	140(Dia.) x 45(H)	87.5(H) x 87.5(W) x 54(D)
Remarks	-	Protection Cover is optional

Agent In Thailand : U.P.TECH CORPORATION CO.,LTD

28 Soi Rattana Thibet 28 Yaek 2 Bangkrasor Muangnonthaburi
Nonthaburi 11000 Thailand

LINE : 0863133492 **Tel** : 02-965-7701-6, 086-355-6781

Email : sales@up-t.com **Email** : admin@up-t.com

Website : www.alarmthailand.com , www.firealarmonline.com

HORING LIH INDUSTRIAL CO., LTD.

4F., No. 18, Lane 327, Chung Shan Road, Sec. 2, Zhonghe District 235, New Taipei City, **Taiwan**

Tel : +886 2 22487599 **Fax** : +886 2 22407752 **Email** : export@horinglih.com **Website** : www.horinglih.com